

TYPE APPROVAL DECISION



Issued 14.9.2020

English version 24.9.2020

Valid until 14.9.2025

Eurofins Expert Services Oy has, based on the act given about the approval of certain construction products (954/2012) 5§ and taking into account the provisions of the chapter 2 and provisions of 1§ of decree given by the Ministry of the Environment on the approval of certain construction products (555/2013), issued the following type approval.

MANUFACTURER

Vieser Oy, Kauhajoki

PRODUCT

Vieser- floor drain system which consist of following parts:

Vieser vertical drain DN50, the nominal outer diameter of the floor drains is DN50, depth of the water seal is 53,5 mm

Vieser low horizontal drain DN50, the nominal outer diameter of the floor drains is DN50, depth of the water seal is 54 mm

Vieser matala horizontal drain DN75, the nominal outer diameter of the floor drains is DN75, depth of the water seal is 54 mm

Vieser extension ring without side inlet

Vieser extension ring 3x32, with three side inlets

Vieser low extension ring 12 mm

Vieser low extension ring 18 mm

Floor drains and other parts are made of polypropylene (PP)

SCOPE OF THE APPROVAL

This approval certifies that the above mentioned floor drains fulfil the requirements set for household waste water installations in the Decree of the Finnish Ministry of Environment 483/2019.

CONDITIONS OF THE APPROVAL

The technical information of the product and the installation instructions shall be delivered with the product.

The installation instructions from the manufacturer shall be followed with the installation.

MARKING

The floor drain shall be identifiable and traceable based on its permanent marking. The manufacturer shall mark the floor drains in a permanent manner so that the markings indicate, as a minimum, the name or identifier of the manufacturer, the date of manufacture and the size of the outlet fitting.

To the product, its packing or documents delivered with the packing shall be marked with an attached type approval mark, type approval

number in a form "20-004251-TH2" and the name and sign of the manufacturer.

VALIDITY PERIOD

The validity of this decision starts on 14.9.2020 and ends no later than on 14.9.2025.

VERIFICATION OF THE QUALITY CONTROL

Verification Body of Quality control

Eurofins Expert Services Oy, Espoo

Quality control contract

Quality contract number VTT-A-00071-17 signed on 27.6.2017 or updated afterwards.

REMARKS

Type Approval decision is public. The list is kept on the websites of the Eurofins Expert Services Oy.

Eurofins Expert Services Ltd acts as a type approval body based on the act given about the approval of certain construction products 18§, authorized by the Finnish Ministry of the Environment and as a certification body (S017) accredited by FINAS.

The floor drains and extension rings have had STF Type Approval RTH-00080-10 which validity has ended 14.9.2020.

Conditions of the validity

If the product enters the CE marking the type approval expires.

The type approval decision is issued for maximum of 5 years at a time.

Eurofins Expert Services requires annual surveillance for the manufacturer's internal quality control in order to verify that the product corresponds to the properties that manufacturer has declared.

The manufacturer is in charge of the product's quality and factory production control. In awarding this certificate, Eurofins Expert Services Oy does not bind itself to indemnification liability concerning personal injury or other damage that may directly or indirectly result from using the product described in this certificate.

The use of the name of Eurofins Expert Services Oy or the name Eurofins in any other form in advertising or distribution in part of this Type Approval is only permissible with a written authorization from Eurofins Expert Services Oy.

**CANCELLATION OF THE
TYPE APPROVAL**

The type approval decision will be cancelled if:

- The construction product does not fulfil the requirements presented in the land use and building act or the technical requirements based on the act.
- The importer or the manufacturer or its representative does not correct the flaws detected by the quality control.
- The usage of the construction product is prohibited by Finnish Safety and Chemicals Agency (Tukes) or the importer or the manufacturer or its representative is ordered to withdraw the product from the markets by Tukes.

BASIS OF THE APPROVAL

The Decree of the Finnish Ministry of Environment of the Type Approval of floor gullies 9/19, valid from 1.1.2020

The Decree of the Finnish Ministry of Environment of the essential technical requirements of floor gullies 483/2019, valid from 1.1.2020

Tiina Ala-Outinen
Development Manager

Tatu Toivonen
Senior Expert
TatuToivonen@eurofins.fi

This document has been signed electronically

This report is the English version of the original Type Approval. In case of dispute the Finnish original report is valid.

ANNEXES

Type approval logo
Rectification demand- and reclamation guide

FOR INFORMATION

Eurofins Expert Services Oy, Quality control