PRODUCT CERTIFICATE

Vieser Oy

manufactures products

Vieser ja Vieser One floor drains

Eurofins Expert Services Oy has assessed the compatibility of Vieser floor drain with liquid applied waterproofing membranes for wet rooms. Assessment is based on watertightness tests according to standard EN 1253-1 or EAD 030352-00-0503. According to the test results, the following waterproofings with their connecting accessories together with Vieser and Vieser One floor drains meet the requirement for watertightness:

Waterproofing membrane	Flange	Manufacturer/Supplier	
ARDEX 8+9	ARDEX STA 40 x 40	ARDEX Oy	
	Vieser membrane flange		
ARDEX S 1-K Plus	ARDEX STA 40 x 40		
	Vieser membrane flange		
Fescon Vedeneriste	Fescon Kaivolaippa KL-B	Fescon Oy	
	Fescon Kaivolaippa 300x300 mm, fabric		
Fescon Vedeneriste WS	Fescon Kaivolaippa KL-B		
Fescoseal A+B	Fescon Kaivolaippa KL-B		
Fintex Vedeneriste 1320	Fintex Lattiakaivovahvike 1326	First av Tatrakara Ov	
	Fintex Lattiakaivomansetti 1327	Fintex-Tetrakem Oy	
Kiilto Kerafiber	Kiilto Kaivolaippa	Kiilto Oy	
	Kiilto Lattiakaivovahvike		
	Vieser membrane flange		
Kiilto KeraPro	Kiilto Lattiakaivovahvike		
Lakka Vedeneriste	Lakka Kaivolaippa	Lakka Rakennustuotteet Oy	
	Lakka Kaivomansetti		
Mapegum WPS	Mapeband B DC	Manai Ov	
	Mapeband B DCL		
Mapeguard WP 2K	Mapeband B DC	─ Mapei Oy	
	Mapeband B DCL		
MaxStop	MaxStop drain gasket	GVK Coating Technology Oy	
mira 4400 multicoat	mira 4550 seal manchet	mira ehitusmaterjalid Oü	
PCI Lastogum	PCI Pecitape WS	BestLevel Oy	
Timpuri	Timpuri Lattiakaivovahvike	Rakennuskemia Oy	
TKR Basic coating and TKR Gel 2	Kiilto Masa sealant in penetration	TKR-Marketing Oy	
Tremco NM 100		Tremco CPG Finland Oy	
weber WP	weber FM Kuitukangas		
	weber DC Kaivolaippa	Saint-Gobain Finland Oy	
weber WX	weber DC Kaivolaippa	7	

This certificate is based on testing of the product according to the Eurofins certification rules SERT R003 and verification of the quality control system related to the product.

This certificate is valid until March 14, 2028 on condition that the products are not essentially changed and the manufacturer and Eurofins Expert Services Oy have a valid contract on quality control. To check the validity of this certificate, www.sertifikaattihaku.fi. Other conditions are given on page 2.

Espoo March	14, 2023
Katja Vahtikari	Tiina Tirkkonen
Manager, Construction Certification	Senior Expert
	This document has been signed electronically

PRODUCT CERTIFICATE

No C73/99/EN Issued June 7, 1999 Updated March 14, 2023

2 (2)

Conditions of validity of the certificate:

Where reference is made in this certificate to any regulations, publications, standards or other documents, it shall be construed as a reference to such publication in the form of which it is in force at the date of this certificate.

The manufacturer is responsible for the quality and continuous quality control of the product. In granting this certificate, Eurofins Expert Services Oy does not accept responsibility to any person or body for any loss or damage incurred in respect of personal injury arising as direct or indirect result of the use of this product.

The use of the name of EurofinsExpert Services Oy or the name Eurofins in any other form in advertising or distribution in part of this certificate is only permissible with written authorisation from Eurofins Expert Services Oy.

This certificate is the English version of the original Finnish certificate No C73/99. In case of dispute, the original Finnish certificate is valid.

